

sieć ciepła 120/65 °C

t_{zew} °C	F	T_z °C	T_p °C
1	2	3	4
-20	1,000	120	65
-19	0,975	118	64
-18	0,950	115	63
-17	0,925	113	62
-16	0,900	110	61
-15	0,875	108	59
-14	0,850	105	58
-13	0,825	103	57
-12	0,800	100	56
-11	0,775	98	55
-10	0,750	95	54
-9	0,725	93	53
-8	0,700	90	52
-7	0,675	88	50
-6	0,650	85	49
-5	0,625	83	48
-4	0,600	80	47
-3	0,575	78	47
-2	0,550	75	47
-1	0,525	73	47
0	5,000	72	47
1	0,475	71	46
2	0,450	70	46
3	0,425	69	46
4	0,400	68	46
5	0,375	67	46
6	0,350	66	46
7	0,325	66	46
8	0,300	65	47
9	0,275	65	47
10	0,250	65	47
11	0,225	65	47
12	0,200	65	47

UWAGA:

Temperatury powrotu są temperaturami max. dopuszczalnymi !